

Mieles, Janette

From: Taylor, Karen
Sent: Tuesday, December 23, 2014 7:13 PM
To: Mcchesney, Dennis; Sawyer, William
Subject: RE: PR UST regs

I suggest you inquire about the following two items:

(1) Rule 833. Release Detection Recordkeeping / 40 CFR 280.45

Deleted from paragraph (C): "Any schedules of required calibration and maintenance provided by the release detection equipment manufacturer must be retained for at least five (5) years from the date of installation."

(2) Rule 919 now has "RESERVED"

Previous PRUST version:

Rule 919. Revocation of authorization

The Board may, in any case of violation of any applicable Rules, suspend, amend or revoke any certification, approval or permit granted under this Regulation.

In General, the TABLE OF CONTENTS (TOC) descriptions do not match the Rule descriptions.

Example:

For the Field Citation, the TOC has Rule 915. Expedited Enforcement Procedures through Orders of Consent In the document the header has Rule 915. Orders of Consent

There are typos throughout the document, but there may be some EQB review for this before publication.